

CERTIFICATE

TÜV NORD CERT GmbH
herewith declares that

Ningbo Taurus Industry Co., Ltd.
NO.69 Xiaxiang Rd(W), Lanjiang Industrial Area, Yuyao,
Zhejiang, China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules




Certification program: P12-VA-01 Rev. 17 09.20
Certification fundamental(s): IEC / EN 61215-1:2016;

Valid from: 2022-12-30
Valid until: 2027-12-29

IEC / EN 61215-1-1:2016;
IEC 61215-2:2016 / EN 61215-2:2017 + AC:2017 + AC:2018;
IEC 61730-1:2016 / EN IEC 61730-1:2018 + AC:2018;
IEC 61730-2:2016 / EN IEC 61730-2:2018 + AC:2018.

Registered No.: 44 780 22 406749 - 267
Manufacturer: see Annex
Test Report No.: 492012266.001
File No.: PVP11016/22P-01

 Digitally signed by
Roger Miao
Date: 2022.12.30
17:48:55 +08'00'

TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2022-12-30

Please also pay attention to the information stated overleaf.


Manufacturer:

Manufacturer: **Ningbo Taurus Industry Co., Ltd.**
NO.69 Xiaxiang Rd(W), Lanjiang Industrial
Area, Yuyao, Zhejiang, China

Factory inspection report no.: 862010428.003

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.


Digitally signed by
Roger Miao
Date: 2022.12.30
17:50:10 +08'00'

TÜV NORD CERT GmbH
Certification Body
Consumer Products

Description of product(s):

Module types:	PV Modules with Half-cut 210mm TOPCon Mono-crystalline Silicon Solar Cells: 132 cells: ODAxxx-33V-MH (xxx=670-700, in increment of 5) 120 cells: ODAxxx-30V-MH (xxx=610-635, in increment of 5) 110 cells: ODAxxx-28V-MH (xxx=560-580, in increment of 5) 100 cells: ODAxxx-25V-MH (xxx=510-530, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	30A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Module types:	PV Modules with Half-cut 182mm TOPCon Mono-crystalline Silicon Solar Cells: 156 cells: ODAxxx-39V-MH (xxx=590-620, in increment of 5) 144 cells: ODAxxx-36V-MH (xxx=550-570, in increment of 5) 132 cells: ODAxxx-33V-MH (xxx=500-525, in increment of 5) 120 cells: ODAxxx-30V-MH (xxx=460-475, in increment of 5) 108 cells: ODAxxx-27V-MH (xxx=410-430, in increment of 5)
Maximum system voltage:	1500V
Fuse rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
Material group:	I
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to ANSI/UL 1703-2018 (as per ANSI/UL 790-2018)

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) in Annex 1 of test report.

Digitally signed by
Roger Miao
Date: 2022.12.30
17:50:37 +08'00'

TÜV NORD CERT GmbH
Certification Body
Consumer Products